MIDDLESEX WATER COMPANY

APPLICATION AND AGREEMENT FOR PRIVATE FIRE PROTECTION SERVICE

Applicant:		Tap Number	
Location of Premises			
	Street Address	Town or City	Zip Code
Mailing Address:			
Phone #	Email:		
Block The undersigned Applicant hereby r	Lot equests a connection for Private	Meter Size Fire Protection Service to the abo	ve described premises.
The Applicant agrees to pay the rate forth in the Tariff for Water Service may be amended, revised or suppler	e on file with the Board of Publ	ic Utility Commissioners of the S	State of New Jersey, as the same
It is understood and agreed that the service is commenced, pursuant to occupancy of the premises or written	this Application, until written	notice is received by the Compa	
Private fire service lines are equippe	d with special meters and shall	be used exclusively for fire protec	tion purposes.
The Applicant understands and agree or definite quantity of water or present opersons or property by reason of f	sure and that the Company shall	be free and exempt from any and	all claims for damages or injury
It is further understood and agreed to party for any loss or damage resulting private fire service connection or a other flow of water from said privated damage resulting from any excess on	ing from fire or water, or other ny pipe or fixture connected the te fire service connection, or an	agency, which may occur due to erewith: or for any loss or damagny of the pipes or fixtures connect	the installation or presence of a ge resulting from any leakage o sted therewith: of for any loss o
		Date:	
Witness or Attest:			
-		SIGNATURE OF APP	PLICANT
Insurance Company:		Policy #	
Insurance Co. Addre	ss:		
Application Received		Date	
FACILITY CHARGE	EXEMPTION REQUESTE	ED: YES/NO	

or or

(Note: If the Applicant is a corporation, this agreement should be signed by the President or Vice President and attested by the Secretary or Assistant Secretary and affix corporate seal.)

SERVICE LINE READY: YES/NO

MIDDLESEX WATER COMPANY PRIVATE FIRE PROTECTION APPLICATION

- Customer must provide copy of SITE PLAN reflecting where the fire service line is being installed.
- Fire Service lines cannot be installed in driveways. (Be it existing or a new install)
- Fire Service lines must be 4 feet from sanitary sewer trench.
- Backflow prevention (RPZ) is required for ALL fire water service lines. The RPZ must be testable, lead-free, and NSF-61 approved and installed in an Above Ground Meter Enclosure (AGME) or Meter Room (WHEN APPROVED BY MWC). The RPZ and meter enclosure are installed, owned, and maintained by the customer and must be approved and installed prior to MWC making any connection.

FOR 2" METER & BELOW

- MWC will install a <u>meter & meter pit in between curb & sidewalk / preference 1</u>; <u>behind the sidewalk / preference 2</u>; <u>or in sidewalk / preference 3</u>. (MWC owns & maintains the meter & pit)
- Customer must submit site plans for determination of meter pit placement.
- If determined meter pit to be installed in sidewalk, the Contractor/Customer must leave out 2 Slabs of concrete sidewalk (not poured) so that the meter pit can be installed.
- MWC Restoration Contractor will restore sidewalk within 30 days of installation of pit weather permitting. (During winter months the 30 days may be extended due to the weather)

FOR 3" METER OR ABOVE

- Meters shall be installed in an above ground, heated meter enclosure, installed, owned and maintained by the customer.
- The meter enclosure must be located within 10 feet of the curb, unless otherwise approved by MWC.
- When MWC permits the meters to be installed inside the customer's commercial, multi-unit dwelling or industrial building, the meters shall be located in a clean, dry, heated, illuminated, safe place not subject to great variations in temperature & within 5 feet to the point of entrance of the connecting pipe.
- The location shall be as close to the curb as possible so as to minimize the unmetered length of the customer's connecting pipe and it shall be separated from the remainder of the premise by a permanent wall with a single exterior entrance such as to be easily accessible by vehicle and personnel via firm paved/concrete surface.
- Meter room can only contain the water metering & related equipment (no other utilities ex. Gas & Electric).
- MWC needs to be able to get a sling on the meter and lift the meter straight up and out of the box. This means it must have a removable roof panel or a hatch in the roof.

IMPORTANT NOTATIONS FOR ALL APPLICATIONS

**** PRIOR TO MWC INSTALLING THE TAP & METER****

Backflow prevention (RPZ) is required for ALL fire water service lines. The RPZ must be installed in an Above Ground Meter Enclosure (AGME) or Meter Room (WHEN APPROVED BY MWC). The RPZ and meter enclosure are installed, owned, and maintained by the customer and must be approved and installed prior to MWC making any connection.

Customer must contact the MWC Engineering Dept at 732-579-6803 or via email at jschoen@middlesexwater.com at least 6 weeks prior to advise that they are ready for the installation of tap & meter. County & State roads may require additional advance notice.

The waiting time of 6 weeks for installation starts from the date the service is inspected & approved by MWC, not the date of the application.

<u>IF MWC FINDS THAT THE SERVICE LINE IS NOT RUN AS INDICATED ON THE SITE PLAN, MWC WILL NOT INSTALL THE WATER SERVICE.</u>

MWC REQUIRES A SIGNATURE WHEN TURNING ON THE WATER. IF NO ONE IS PRESENT THE WATER WILL NOT BE TURNED ON AT THE CURB WHEN INSTALLATION IS COMPLETE

I have received the above information:			
Date:			